

**Declaration of Performance  
DoP AB-CI-en**



1. Product type: Fire-rated collar for multiple diameters
2. Identification: 

Code
AF MULTICOLLAR / ABCIKIT25
3. Intended use: Fire sealant for the protection of combustible pipe passages (see ETA 16/0771)
4. Distributor: Index Fixing Systems. Técnicas Expansivas S.L.  
C/Segador, nº13  
26006 Logroño, La Rioja, ESPAÑA
5. Authorised representative: Not applicable
6. System of assessment of performance: 1
7. Harmonized standard: Not applicable
8. European technical assessment: European assessment document: ETAG 026 Part 1 - 2, April 2011 edition  
European Technical Assessment ETA: ETA 16/0771 of 30/07/2019  
Technical evaluation body: Institute of Construction Technology of Catalonia - ITEC
9. Declared performance:

Essential characteristics	Performance
Fire reaction	E according to EN 13501-1 See ETA 16/0771 - point 3.2.1.
Fire Resistance	EI 120-180 according to EN 13501-2. See ETA 16/0771, Annex B, point 3.2.2
Duration and service	Y2 according to ETAG 026-2, section 2.4.12 See ETA 16/0771 - section 3.2.3.

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9

This declaration of performance is issued under the sole responsibility of the distributor identified in point 4.

Signed on behalf of the manufacturer by:

Santiago Reig. Technical manager.  
Logroño, 20.01.2020